

# CERTIFICATE FI/41480

Our Ref. HEL-CERT220801293-01



**Product** Heating cable  
**Type** FPC-CT  
**Trademark** THERMALINT  
**Certificate Holder** Thermaflex Izolacji Sp. z o. o  
Przemysłowa 6  
58-130, Zarow, Poland  
**Technical information** Max. 40 W/m, 300/500 V  
Rated temperature 105 °C, Class M2  
With cold lead, splice and end seal

**Other information** See page 2 of this Certificate

**The product is certified according to the following standard(s)** IEC 60800:2021

**Validity** This certificate is valid until 2027-09-13 provided that the Conditions for FI certification are met. This certificate includes the right to use the FI mark under the condition that changes (if any) will be checked at SGS Fimko before the product is brought onto market and that the conditions for FI certification are met.

**Date of issue** 13 September 2022

**SGS Fimko Ltd**

**Signature**



Seppo Lautamies  
Project Manager



**Manufacturer** Thermopads Pvt. Ltd.  
 Plot No: 28, Nagarjuna Hills  
 500 082, Punjagutta, Hyderabad, India

**Manufacturing site** Thermopads Pvt. Ltd.  
 F 10/ B, 12B, 14A & B  
 IDA Phase I, Jeedimetla  
 500055, Hyderabad, Telangana, India

**Additional information** FPC-CT FPC with thermostat

**Construction:**

- heating conductor, solid/stranded
- insulation, fluoropolymer or XLPE
- metal shielding
- outer sheath, polyolefin/PVC or zero halogen compound

**Joints and terminations** IPX7  
 For fixed supply or with plug

**Based on:** HELES2107000763-1